

# CONSUMER CONFIDENCE REPORT

## TCEQ CERTIFICATION of DELIVERY

*For Calendar year 2016*

**Public Water System(PWS) Name :** CITY OF COLLINSVILLE

**PWS ID Number :** TX0910005

I certify that the community water system named above has distributed the Consumer Confidence Report (CCR) for the calendar year of 2016 and that the information in the report is correct and consistent with the compliance monitoring data previously submitted to the TCEQ. Public Water Systems **servicing 500 or fewer persons** are not required to mail the entire CCR to their customers as long as the system provides notice at least once per year by July 1 to its customers by mail, door-to-door delivery, or by posting in an appropriate location that the report is available upon request.

Date of Delivery: \_\_\_/\_\_\_/\_\_\_  
 Certified By: Name (print): \_\_\_\_\_  
 Title: \_\_\_\_\_  
 Phone Number: (\_\_\_\_) \_\_\_-\_\_\_\_ Email: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_/\_\_\_/\_\_\_

**Direct delivery methods**-You must use at least one direct delivery method (check all that apply):

- Mail a paper copy of the CCR.
- Electronic Delivery:**
- Mail notification that CCR is available on-line at [http://\\_\\_\\_\\_\\_](http://_____)
- Email direct web address of the CCR, available at [http://\\_\\_\\_\\_\\_](http://_____)
- Email CCR as an attachment to an email.
- Email CCR as an embedded image in an email.
- Other direct delivery (for example, door hangers or additional electronic delivery method).

Please specify: \_\_\_\_\_

**Good-faith delivery methods** -To reach people who do not receive bills (check all that apply):

- Posting the CCR on the Internet at [http://\\_\\_\\_\\_\\_](http://_____)
- Mailing the CCR to people who receive mail, but who do not receive bills.
- Advertising the availability of the CCR in news media.
- Posting the CCR in public places.
- Delivering multiple copies to single billing addresses serving multiple persons.
- Delivering multiple copies of the CCR to community organizations.

\*Systems serving 100,000 or more people are required to post the CCR on a publicly available web site and provide the URL here: [http://\\_\\_\\_\\_\\_](http://_____)

**All systems are required to mail by July 1 the certification of delivery and complete Consumer Confidence Report to:** TCEQ recommends the use of certified mail.

Sending by certified mail:	Sending by regular mail:
TCEQ PDW, MC-155, Attn: CCR, 12100 Park 35 Circle Austin, TX 78753	TCEQ PDW, MC-155, Attn: CCR, PO Box 13087 Austin, TX 78711-3087

# Annual Drinking Water Quality Report

TX0910005

CITY OF COLLINSVILLE

Annual Water Quality Report for the period of January 1 to December 31, 2016

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

For more information regarding this report contact:

Name: Mark Patterson

Phone: 903-429-6225

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono 903-429-6225.

CITY OF COLLINSVILLE is Ground Water

## Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your

physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

### **Information about Source Water Assessments**

The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants may be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system, contact Mark Patterson.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL: <http://tceq.state.tx.us/gis/swaview>

Further details about sources and source-water assessments are available in Drinking Water Watch at the following URL: <http://dww2.tceq.texas.gov/DWW>

Source Water Name		Type of Water	Report Status	Location
2 - WOODLAND PS / 100 BLK E FM 902		GW	Active	Trinity Aquifer
4 - 200 BLK S MAIN	200 BLK S MAIN	GW	Active	Trinity Aquifer
5 - ELM PS / 300 BLK W ELM	PS 2	GW	Active	Trinity Aquifer
6 - BROADWAY / REEVES	PS3	GW	Active	Trinity Aquifer
7 - PARK LN / E SIDE OF TOWN		GW	Active	Trinity Aquifer

**2016 Regulated Contaminants Detected**

**Lead and Copper**

Definitions:

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	06/10/2015	1.3	1.3	0.069	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.

**Water Quality Test Results**

Definitions:	The following tables contain scientific terms and measures, some of which may require explanation.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Level 1 Assessment:	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Level 2 Assessment:	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MFL	million fibers per liter (a measure of asbestos)
na:	not applicable.
mrem:	millirems per year (a measure of radiation absorbed by the body)
NTU	nephelometric turbidity units (a measure of turbidity)
pCi/L	picocuries per liter (a measure of radioactivity)
ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.
ppt	parts per trillion, or nanograms per liter (ng/L)
ppq	parts per quadrillion, or picograms per liter (pg/L)

## Regulated Contaminants

<b>Disinfectants and Disinfection By-Products</b>	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
<b>Haloacetic Acids (HAA5)</b>	2016	4	4.3 - 4.3	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
<b>Total Trihalomethanes (TTHM)</b>	2016	4	4.14 - 4.14	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
<b>Inorganic Contaminants</b>	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
<b>Barium</b>	05/07/2015	0.01	0.0093 - 0.01	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
<b>Chromium</b>	05/07/2015	2.4	0 - 2.4	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
<b>Fluoride</b>	05/07/2015	0.229	0.206 - 0.229	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
<b>Selenium</b>	05/07/2015	2	0 - 2	50	50	ppb	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.
<b>Radioactive Contaminants</b>	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
<b>Combined Radium 226/228</b>	03/28/2012	1	1 - 1	0	5	pCi/L	N	Erosion of natural deposits.

## Chlorine Residuals - 2016

<b>Disinfectant</b>	Average Level	Highest Level Detected	Lowest Level Detected	MRDL	MRDLG	Units	Violation	Likely Source of Contamination
<b>Free Chlorine</b>	1.12	2.01	.21	4.0	<4.0	ppm	N	Water additive used to control microbes

## Water Loss – 2015

In the water loss audit submitted to the Texas Water Development Board for the time-period of January – December 2015, our system lost an estimated 5,672,161 gallons of water or 8.59% of total water produced. If you have any questions about the water loss audit please call 903-429-3008.